



# Fire & Life Safety Inspection - Pre-remodel

Date: 3/18/26 Occupancy Name: Eudora Library (New) Phone: \_\_\_\_\_

Address: 736 Main Street Email: \_\_\_\_\_ Re-Inspection

Contact Name: Kenny Massey After Hours Contact: \_\_\_\_\_

Occupancy Classification						
Assembly	A-1 <input type="checkbox"/>	A-2 <input type="checkbox"/>	A-3 <input checked="" type="checkbox"/>	A-4 <input type="checkbox"/>	A-5 <input type="checkbox"/>	Business <input type="checkbox"/>
High Hazard	H-1 <input type="checkbox"/>	H-2 <input type="checkbox"/>	H-3 <input type="checkbox"/>	H-4 <input type="checkbox"/>	H-5 <input type="checkbox"/>	Educational <input type="checkbox"/>
Residential	R-1 <input type="checkbox"/>	R-2 <input type="checkbox"/>	R-3 <input type="checkbox"/>	R-4 <input type="checkbox"/>		Mercantile <input type="checkbox"/>
Institutional	I-1 <input type="checkbox"/>	I-2 <input type="checkbox"/>	I-3 <input type="checkbox"/>	I-4 <input type="checkbox"/>		Utility / Miscellaneous <input type="checkbox"/>
Factory / Industrial	F-1 <input type="checkbox"/>	F-2 <input type="checkbox"/>				Storage <input type="checkbox"/>
						S-1 <input type="checkbox"/>
						S-2 <input type="checkbox"/>

Pass	Fail	N/A	Exterior Inspection
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Address visible from public way (Minimum 6" high 1/2" stroke) - IFC 505.1
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Knox Box present w/ appropriate keys - IFC 506
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fire apparatus access roads and lanes unobstructed and clearly marked - IFC 503.1
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fire Lanes marked / unobstructed - IFC 503.3
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	FDC labeled, maintained, and free from obstructions - IFC 912
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Access to fire hydrant / free from obstructions - IFC 507.5
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Private Fire hydrants maintained, inspected, and tested annually - IFC 507.5

Pass	Fail	N/A	Egress
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Adequate number of Exits - IFC 1006
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Means of Egress unobstructed (not reduced / blocked) - IFC 1001.2, 1028.1, and 1031.1
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Exit doors easily opened from egress side/No deadbolts/Panic hardware over 50 occupants - IFC 1010
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Doors swing in direction of egress (over 50 occupants) - IFC 1010.1.2.1 <i>Roof doors inward</i>
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Exit signage installed / in good repair - IFC 1013
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Emergency lighting present and illuminating Exit access, Exit, Exit discharge - IFC 1008
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Combustible storage clear from beneath exit stairs - IFC 315.3

Pass	Fail	N/A	General Precautions
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Good general house keeping, (no accumulation of combustible waste, rubbish, paper, wood, grease, etc...) - IFC 304.1
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	No Smoking signage visible and legible in high hazard areas - IFC 310.1
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Vacant premises safeguarded - IFC 311.2
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Indoor fixtures and displays not obstructing exits/no highly combustible goods within 5' of exits - IFC 314.1
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	General storage maintained 24" below ceiling, 18" if sprinklered bldg (exception-along walls) - IFC 315.3.1

Pass	Fail	N/A	Fire Protection Construction Features
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fire rated construction present / maintained - IFC 703.1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Fire rated doors operational (not blocked open) - IFC 705
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Joints/Void openings protected - IFC 704.2
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Decorations (foams, curtains, drapes, hangings) to be flame resistant in specific occupancies - IFC 807.1

Pass	Fail	N/A	Fire Prevention / Fire Protection
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Emergency plan has been reviewed by AHJ - IFC 401.2
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Fire and Evacuation plans posted - IFC 404
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Emergency Evacuation drills conducted quarterly and documented - IFC 405
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Access to building openings and roofs - IFC 504
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Fire protection & utility rooms identified and access compliant - IFC 509.1
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Elevator operation, maintenance, fire service key is compliant and official state certification available.
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Fire alarms inspected, tested, and maintained - IFC 907.8
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Sprinkler systems inspected, tested, and maintained by licensed company - IFC 901.6
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Water supply valves accessible and locked in the "ON" position - IFC 913.4
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Fire extinguishers visually inspected monthly / tested annually - IFC 901.6
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Fire extinguishers available, visible, and unobstructed - IFC 906.5
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Travel distance to fire extinguisher not exceeded - IFC 906.3
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Smoke detectors are in proper locations and tested periodically - NFPA 72
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Commercial kitchen hood(s)-Operations, cleaning, and maintenance records and current system inspection - IFC 904.12

Type of cooking operation		Commercial cooking system inspection and cleaning frequency	
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Pass	Fail	N/A	Electrical Equipment, Wiring, and Hazards
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Hood system fuel shut off visible and accessible - IFC 904.12.2
<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Wet-chemical extinguishing system operational with current system inspection tag - IFC 904.5

**Identified electrical hazards shall be corrected immediately. Any electrical wiring, devices, appliances, and other equipment that is modified or damaged constitutes an electrical shock or fire hazard and shall not be used.**

<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	No electrical hazards - IFC 604.1
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Electrical room and panels are labeled - IFC 604.3.1
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Power strips are grounded, connected to permanently installed receptacle, not overloaded - IFC 604.4
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Extension cords not used as permanent wiring, extended through walls, doors, windows, or under flooring - IFC 604.5
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Extension cords used only for portable appliances and not overloaded - IFC 604.5
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Switches, outlet and junction boxes properly covered - IFC 604.7
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Portable / electric space heaters plugged directly into receptacle, no extension cord, and 3' clear of combustibles - IFC 604.10
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Abandoned wiring removed, unused wiring tagged and secured - IFC 604.11
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Access and 36" clearance around electrical service equipment - IFC 604.3

Fire Inspector: \_\_\_\_\_

Property Representative: \_\_\_\_\_